



OFFICE OF THE GENERAL MANAGER, WATCO DIVISION, BERHAMPUR

e-mail: gmwatcobam@nic.in / Ph No. 06802233978

Letter No.

1472

Date. 13.03.26

To
The Principal
De Paul School
Gopalpur-on-Sea
Ganjam, Odisha

Subject: Issuance of Water Test Certificate

Sir/Madam,

With reference to your letter No. DPSG/113/25-26 dated 05.02.2026 regarding the request for issuance of a Water Test Certificate for the building situated at Khata No. 12, Plot No. 47 under Gopalpur, this is to inform you that the water sample from the said premises has been examined as per the prescribed procedure.

Based on the test results and verification of the available water supply facilities, it is certified that the water quality meets the required standards for the intended use as per the applicable norms.

Accordingly, the Water Test Certificate for the above-mentioned premises is hereby issued for official purposes.

This certificate is issued on the basis of the test conducted and is subject to compliance with the relevant rules and regulations.

Enclosure: Water test report from Spectro analytical Labs Pvt. Ltd.

Dr. Gini
Manager
DE PAUL SCHOOL
Gopalpur-on-Sea

George
Secretary
Vincentian Board of Education
Berhampur-760010
Odisha, India

Sam
Principal
De Paul School
Gopalpur-on-Sea

JB
13/3/26
General Manager
WATCO Division
Berhampur
General Manager
WATCO Division
Berhampur

Under PPP Mode, Govt. of Odisha.

TEST REPORT

Customer Name & Address: DE PAUL School Gopalpur, Gopalpur On Sea, 761002	Test Report No.: BHMR09032026/LTR-010	
Contact Person: Mr. Mathew Nayak	Contact No.: 8908765975	
E.mail ID:gopalpurdpsg@gmail.com	Date of Sample Receipt:09.03.2026	
Type of Sample (Source) : Drinking Water (bore well)	Sample Quantity (Received): 1 Ltr	
Sampling Location: Gopalpur On Sea	Date of Start of Testing: 09.03.2026	
Sample Condition: Good	Date of Completion of Test: 12.03.2026	
Sample Submitted at Laboratory By: Customer	Test Report Issue Date: 13.03.2026	
Special Instruction (If Any): No	Sample ID: BHMR260309/LTR-010	
Customer reference No. & Date: As per Contract.	Total No. Pages	Page No.:
	02	Page 01 of 02

4. (Chemical Testing – Water) -

TEST RESULTS

Sr. No	TEST PARAMETERS	TEST METHODS	OBSERVED RESULTS	Limits Max. (as per IS 10500)	
				Acceptable Limit	Permissible Limit in the Absence of Alternate Source
1	pH, at 25 °C	IS 3025 (Pt-11), 2022	6.9	6.5 - 8.5	No relaxation
2	Total Dissolved Solids (mg/l), at 180 °C	IS 3025 (Pt-16), 2023	22	500 mg/l	2000 mg/l
3	Total Alkalinity (as CaCO ₃), mg/l	IS 3025 (Pt-23), 2023	20	200 mg/l	600 mg/l
4	Total Hardness (as CaCO ₃), mg/l	IS 3025 (Pt-21) 2009, RA - 2019	45	200 mg/l	600 mg/l
5	Chlorides (as Cl), mg/l	IS 3025 (Pt-32) 1988, (Cl. 2), RA -2019	14.49	250 mg/l	1000 mg/l
6	Residual Free Chlorine, (mg/l)	IS 3025 (Pt-26),(Cl.7.2), 2021	*BDL	0.2 mg/l	1 mg/l
7	Iron (as Fe), mg/l	IS 3025 (Pt-53) 2024 (Cl.6)	0.07	1.0 mg/l	No relaxation
8	Fluoride (as F ⁻), mg/l	APHA 24 th Edition 4500 F ⁻ (D), 2023	*BDL	1.0 mg/l	1.5 mg/l
9	Phosphate (as PO ₄ ³⁻), mg/l	APHA 24 th Edition 4500- P (C), 2023	*BDL	NA	NA
10	Sulphide (as H ₂ S), mg/l	IS 3025 (Pt-29), 2022 (Cl. 7)	*BDL	0.05 mg/l	No relaxation

*BDL- Below Detection Limit. (Detection Limit for RFC-0.2 mg/l, Fluoride-0.05mg/l, Phosphate- 0.2 mg/l Sulphide-0.02 mg/l,)


Secretary
Vincentian Board of Education
Berhampur-760010
Odisha, India


Manager
DE PAUL SCHOOL
Gopalpur-on-Sea


Principal
De Paul School
Gopalpur-on-Sea

Under PPP Mode, Govt. of Odisha.

TEST REPORT

Customer Name & Address DE PAUL School Gopalpur, Gopalpur On Sea, 761002	Test Report No.: BHMR09032026/LTR-010	
	Sample ID No.: BHMR260309/LTR-10	
Special Instruction (If Any): No	Total No. Pages	Page No.:
	02	Page 02 of 02

2. (Biological Testing – Water)

TEST RESULTS

Sr. No.	TEST PARAMETERS	TEST METHODS	OBSERVED RESULTS	Limits Max. (as per IS 10500)
				Acceptable Limit
1	E.Coli (CFU/100 ml)	IS: 15185	<1 CFU	Absent/100 ml

NOTE-< 1: Not detected in 100ml.

- Remarks:**
1. Test results are related to the sample submitted by the customer only.
 2. Test report refers to the values obtained at the time of testing & results are related to the sample tested as above under the stated condition.
 3. The report shall not be reproduced in part / full without written consent of the laboratory.

----- End of Report -----



Reviewed and Authorized By

(Puja Rani Pradhan), HOD Biological



Reviewed and Authorized By

(Binayak Mohapatra), HOD Chemical

George
Secretary

Vincentian Board of Education
Berhampur-760010
Odisha, India

Sm 2
Principal
De Paul School
Gopalpur-on-Sea