

Under PPP Mode, Govt. of Odisha.

TEST REPORT

Customer Name & Address: DE PAUL School Gopalpur, Gopalpur On Sea, 761002	Test Report No.: BHMR09032026/LTR-010	
Contact Person: Mr. Mathew Nayak	Contact No.: 8908765975	
E.mail ID:gopalpurdpsg@gmail.com	Date of Sample Receipt:09.03.2026	
Type of Sample (Source) : Drinking Water (bore well)	Sample Quantity (Received): 1 Ltr	
Sampling Location: Gopalpur On Sea	Date of Start of Testing: 09.03.2026	
Sample Condition: Good	Date of Completion of Test: 12.03.2026	
Sample Submitted at Laboratory By: Customer	Test Report Issue Date: 13.03.2026	
Special Instruction (If Any): No	Sample ID: BHMR260309/LTR-010	
Customer reference No. & Date: As per Contract.	Total No. Pages	Page No.:
	02	Page 01 of 02

4. (Chemical Testing – Water) –

TEST RESULTS

Sr. No	TEST PARAMETERS	TEST METHODS	OBSERVED RESULTS	Limits Max. (as per IS 10500)	
				Acceptable Limit	Permissible Limit in the Absence of Alternate Source
1	pH, at 25 °C	IS 3025 (Pt-11), 2022	6.9	6.5 - 8.5	No relaxation
2	Total Dissolved Solids (mg/l), at 180 °C	IS 3025 (Pt-16), 2023	22	500 mg/l	2000 mg/l
3	Total Alkalinity (as CaCO ₃), mg/l	IS 3025 (Pt-23), 2023	20	200 mg/l	600 mg/l
4	Total Hardness (as CaCO ₃), mg/l	IS 3025 (Pt-21) 2009, RA - 2019	45	200 mg/l	600 mg/l
5	Chlorides (as Cl), mg/l	IS 3025 (Pt-32) 1988, (Cl. 2), RA -2019	14.49	250 mg/l	1000 mg/l
6	Residual Free Chlorine, (mg/l)	IS 3025 (Pt-26),(Cl.7.2), 2021	*BDL	0.2 mg/l	1 mg/l
7	Iron (as Fe), mg/l	IS 3025 (Pt-53) 2024 (Cl.6)	0.07	1.0 mg/l	No relaxation
8	Fluoride (as F ⁻), mg/l	APHA 24 th Edition 4500 F ⁻ (D), 2023	*BDL	1.0 mg/l	1.5 mg/l
9	Phosphate (as PO ₄ ³⁻), mg/l	APHA 24 th Edition 4500- P (C), 2023	*BDL	NA	NA
10	Sulphide (as H ₂ S), mg/l	IS 3025 (Pt-29), 2022 (Cl. 7)	*BDL	0.05 mg/l	No relaxation

*BDL- Below Detection Limit. (Detection Limit for RFC-0.2 mg/l, Fluoride-0.05mg/l, Phosphate- 0.2 mg/l Sulphide-0.02 mg/l,)


Secretary
Vincentian Board of Education
Berhampur-760010
Odisha, India


Manager
DE PAUL SCHOOL
Gopalpur-on-Sea


Principal
DePaul School
Gopalpur-on-Sea

Under PPP Mode, Govt. of Odisha.

TEST REPORT

Customer Name & Address DE PAUL School Gopalpur, Gopalpur On Sea, 761002	Test Report No.: BHMR09032026/LTR-010	
	Sample ID No.: BHMR260309/LTR-10	
Special Instruction (If Any): No	Total No. Pages	Page No.:
	02	Page 02 of 02

2. (Biological Testing – Water)

TEST RESULTS

Sr. No.	TEST PARAMETERS	TEST METHODS	OBSERVED RESULTS	Limits Max. (as per IS 10500)
				Acceptable Limit
1	E.Coli (CFU/100 ml)	IS: 15185	<1 CFU	Absent/100 ml

NOTE-< 1: Not detected in 100ml.

- Remarks:**
1. Test results are related to the sample submitted by the customer only.
 2. Test report refers to the values obtained at the time of testing & results are related to the sample tested as above under the stated condition.
 3. The report shall not be reproduced in part / full without written consent of the laboratory.

----- End of Report -----



Reviewed and Authorized By
(Puja Rani Pradhan), HOD Biological



Reviewed and Authorized By
(Binayak Mohapatra), HOD Chemical

George

Secretary
Vincentian Board of Education
Berhampur-760010
Odisha, India

Principal
Principal
De Paul School
Gopalpur-on-Sea

Manager
Manager
DE PAUL SCHOOL
Gopalpur-on-Sea